§ 292.203

at least some of which is then used for power production.

(Energy Security Act, Pub. L. 96-294, 94 Stat. 611 (1980) Public Utility Regulatory Policies Act of 1978, 16 U.S.C. 2601, et seq., Energy Supply and Environmental Coordination Act, 15 U.S.C. 791 et seq., Federal Power Act, as amended, 16 U.S.C. 792 et seq., Department of Energy Organization Act, 42 U.S.C. 7101 et seq., E.O. 12009, 42 FR 46267)

[45 FR 17972, Mar. 20, 1980, as amended at 45 FR 33958, May 21, 1980; 45 FR 66789, Oct. 8, 1980; Order 135, 46 FR 19231, Mar. 30, 1981; 46 FR 32239, June 22, 1981; Order 499, 53 FR 27002, July 18, 1988; Order 575, 60 FR 4857, Jan. 25, 1995]

§ 292.203 General requirements for qualification.

- (a) Small power production facilities. Except as provided in paragraph (c) of this section, a small power production facility is a qualifying facility if it:
- (1) Meets the maximum size criteria specified in §292.204(a);
- (2) Meets the fuel use criteria specified in §292.204(b); and
- (3) Has filed with the Commission a notice of self-certification, pursuant to §292.207(a); or has filed with the Commission an application for Commission certification, pursuant to §292.207(b)(1), that has been granted.
- (b) Cogeneration facilities. A cogeneration facility, including any diesel and dual-fuel cogeneration facility, is a qualifying facility if it:
- (1) Meets any applicable operating and efficiency standards specified in §292.205(a) and (b); and
- (2) Has filed with the Commission a notice of self-certification, pursuant to §292.207(a); or has filed with the Commission an application for Commission certification, pursuant to §292.207(b)(1), that has been granted.
- (c) Hydroelectric small power production facilities located at a new dam or diversion. (1) A hydroelectric small power production facility that impounds or diverts the water of a natural watercourse by means of a new dam or diversion (as that term is defined in §292.202(p)) is a qualifying facility if it meets the requirements of:
 - (i) Paragraph (a) of this section; and
 - (ii) Section 292.208.

(2) [Reserved]

[45 FR 17972, Mar. 20, 1980, as amended by Order 70–E, 46 FR 33027, June 26, 1981; 52 FR 5280, Feb. 20, 1987; 52 FR 9161, Mar. 23, 1987; Order 478, 52 FR 28467, July 30, 1987; Order 499, 53 FR 27002, July 18, 1988; Order 541, 57 FR 21734, May 22, 1992; Order 671, 71 FR 7868, Feb. 15, 20061

§ 292.204 Criteria for qualifying small power production facilities.

- (a) Size of the facility—1) Maximum size. There is no size limitation for an eligible solar, wind, waste or facility, as defined by section 3(17)(E) of the Federal Power Act. For a non-eligible facility, the power production capacity for which qualification is sought, together with the power production capacity of any other non-eligible small power production facilities that use the same energy resource, are owned by the same person(s) or its affiliates, and are located at the same site, may not exceed 80 megawatts.
- (2) Method of calculation. (i) For purposes of this paragraph, facilities are considered to be located at the same site as the facility for which qualification is sought if they are located within one mile of the facility for which qualification is sought and, for hydroelectric facilities, if they use water from the same impoundment for power generation.
- (ii) For purposes of making the determination in clause (i), the distance between facilities shall be measured from the electrical generating equipment of a facility.
- (3) Waiver. The Commission may modify the application of paragraph (a)(2) of this section, for good cause.
- (b) Fuel use. (1)(i) The primary energy source of the facility must be biomass, waste, renewable resources, geothermal resources, or any combination thereof, and 75 percent or more of the total energy input must be from these sources.
- (ii) Any primary energy source which, on the basis of its energy content, is 50 percent or more biomass shall be considered biomass.
- (2) Use of oil, natural gas and coal by a facility, under section 3(17)(B) of the Federal Power Act, is limited to the minimum amounts of fuel required for ignition, startup, testing, flame stabilization, and control uses, and the

minimum amounts of fuel required to alleviate or prevent unanticipated equipment outages, and emergencies, directly affecting the public health, safety, or welfare, which would result from electric power outages. Such fuel use may not, in the aggregate, exceed 25 percent of the total energy input of the facility during the 12-month period beginning with the date the facility first produces electric energy and any calendar year subsequent to the year in which the facility first produces electric energy.

(Energy Security Act, Pub. L. 96–294, 94 Stat. 611 (1980) Public Utility Regulatory Policies Act of 1978, 16 U.S.C. 2601, et seq., Energy Supply and Environmental Coordination Act, 15, U.S.C. 791, et seq., Federal Power Act, as amended, 16 U.S.C. 792 et seq., Department of Energy Organization Act, 42 U.S.C. 7101, et seq.; E.O. 12009, 42 FR 46267)

[45 FR 17972, Mar. 20, 1980, as amended by Order 135, 46 FR 19231, Mar. 30, 1981; Order 575, 60 FR 4857, Jan. 25, 1995]

§ 292.205 Criteria for qualifying cogeneration facilities.

- (a) Operating and efficiency standards for topping-cycle facilities—(1) Operating standard. For any topping-cycle cogeneration facility, the useful thermal energy output of the facility must be no less than 5 percent of the total energy output during the 12-month period beginning with the date the facility first produces electric energy, and any calendar year subsequent to the year in which the facility first produces electric energy.
- (2) Efficiency standard. (i) For any topping-cycle cogeneration facility for which any of the energy input is natural gas or oil, and the installation of which began on or after March 13, 1980, the useful power output of the facility plus one-half the useful thermal energy output, during the 12-month period beginning with the date the facility first produces electric energy, and any calendar year subsequent to the year in which the facility first produces electric energy, must:
- (A) Subject to paragraph (a)(2)(i)(B) of this section be no less than 42.5 percent of the total energy input of natural gas and oil to the facility; or
- (B) If the useful thermal energy output is less than 15 percent of the total

energy output of the facility, be no less than 45 percent of the total energy input of natural gas and oil to the facility.

- (ii) For any topping-cycle cogeneration facility not subject to paragraph (a)(2)(i) of this section there is no efficiency standard.
- (b) Efficiency standards for bottomingcycle facilities. (1) For any bottomingcycle cogeneration facility for which any of the energy input as supplementary firing is natural gas or oil, and the installation of which began on or after March 13, 1980, the useful power output of the facility during the 12-month period beginning with the date the facility first produces electric energy, and any calendar year subsequent to the year in which the facility first produces electric energy must be no less than 45 percent of the energy input of natural gas and oil for supplementary firing.
- (2) For any bottoming-cycle cogeneration facility not covered by paragraph (b)(1) of this section, there is no efficiency standard.
- (c) Waiver. The Commission may waive any of the requirements of paragraphs (a) and (b) of this section upon a showing that the facility will produce significant energy savings.
- (d) Criteria for new cogeneration facilities. Notwithstanding paragraphs (a) and (b) of this section, any cogeneration facility that was either not certified as a qualifying cogeneration facility on or before August 8, 2005, or that had not filed a notice of self-certification, self-recertification or an application for Commission certification or Commission recertification as a qualifying cogeneration facility under §292.207 of this chapter prior to February 2, 2006, and which is seeking to sell electric energy pursuant to section 210 of the Public Utility Regulatory Policies Act of 1978, 16 U.S.C. 824a-1, must also show:
- (1) The thermal energy output of the cogeneration facility is used in a productive and beneficial manner; and
- (2) The electrical, thermal, chemical and mechanical output of the cogeneration facility is used fundamentally for industrial, commercial, residential or institutional purposes and is not intended fundamentally for sale to an